LISTING SERVICE

LISTING No: 7135-1517:104   Page 1 of 1

CATEGORY: Audible Signal Device

LISTEE: Commercial Products Group, *1130 Milepost Dr., Columbus, OH 43228
                          Contact: Andrew Keller (309) 762-0731

DESIGN: Model FHEX horn. Suitable for indoor or outdoor use. Refer to listee's data sheet for detailed
                          product description and operational considerations. Additional information may also be located
                          in UL Hazardous Location Equipment Directory and UL Fire Protection Equipment Directory.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances
                          and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as an audible device for use with separately listed compatible control units. Suitable for
                          use in hazardous location Class I, Groups C and D, or Class II, Groups E, F and G.

                          If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm
                          Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the
                          appliance must be used with a fire alarm control unit that can generate the temporal pattern
                          signal. Refer to manufacturer's Installation Manual for details.

XLF: 7135-0811:104

*Corrected 12-09-98

Date Issued: **JUNE 10, 2003**   *Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
                          Program Manager